

Computer Models For Fire and Smoke

| | |
|--------------------------------|---|
| <i>Model Name:</i> | ASET-B (Available Safe Egress Time – Basic) |
| <i>Version:</i> | 1.0 |
| <i>Classification:</i> | Zone Model |
| <i>Very Short Description:</i> | A simple, user-friendly, one-room smoke-filling zone fire model which predicts the smoke layer thickness and temperature due to a fire of time-dependent, user-specified, energy release-rate; and solves the same fundamental equations of the ASET model. |
| <i>Modeler, Organization:</i> | W.D. Walton, Building and Fire Research Laboratory, National Institute of Standards and Technology. |
| <i>References:</i> | <p>Walton, W.D., ASET-B: A Room Fire Program for Personal Computers, NBSIR 85-3144-1, National Institute of Standards and Technology (formerly National Bureau of Standards), Gaithersburg, MD, 1985.</p> <p>Cooper, L.Y., “A Mathematical Model for Estimating Available Safe Egress Time in Fires”, <i>Fire and Materials</i>, Vol. 6, pp. 135-144, 1982.</p> <p>Cooper, L.Y. and Stroup, D., “ASET-A Computer Program for Calculating Available Safe Egress Time in Fires”, <i>Fire Safety Journal</i>, Vol. 9, pp. 29-45, 1985.</p> <p>ASET-B: A Room Fire Program for Personal Computers, <i>Fire Technology</i>, Vol. 21 (4), 293-309, Nov. 1985.</p> |
| <i>Availability:</i> | Source code listed in Reference 1, above. Source code and executable program available from http://fire.nist.gov . |
| <i>Price:</i> | There is no cost from NIST for the download. |

Necessary Hardware: The executable program runs on an IBM PC or compatible computer that supports DOS. The source code compiles on a computer that supports BASIC.

Computer Language: BASIC.

Size: 64K RAM.

Contact Information: Doug Walton, (301) 975-6872, dwalton@nist.gov

Detailed Description:

ASET-B is simple, user-friendly, one-room zone fire model which predicts the smoke layer thickness and temperature due to a fire of time-dependent, user-specified, energy release rate. ASET-B solves the same fundamental equations as the ASET model, although it uses a different solution technique. The program is supported by the user's guide of reference 1. The ASET-B input data include the height and area of the room, the elevation of the fire above the floor, and a heat loss factor. ASET-B models the fire growth rate by using pairs of user-specified data points (energy generation rate, time) with linear interpolation between them.