

Computer Models For Fire and Smoke

<i>Model Name:</i>	G-JET
<i>Version:</i>	2.0
<i>Date:</i>	2003
<i>Classification:</i>	Smoke Detection Model
<i>Very Short Description:</i>	Design tool for all categories of smoke detectors to predict their response to performance requirements in applications.
<i>Modeler(s), Organization(s):</i>	Geir Jensen, Elin Tørle Lønvik, COWI AS (InterConsult)
<i>User's Guide:</i>	Self-explanatory web-browser user interface on web-site.
<i>Technical References:</i>	<ol style="list-style-type: none">1 Jensen, Geir: <i>Application Specific Sensitivity: A Simple Engineering Model to Predict Response of Installed Smoke Detectors</i>. Proceedings of AUBE '99. Duisburg. 1999.2 Additional papers available at G-JET website, see below.
<i>Validation References:</i>	G-JET complies with basic formulas and assumptions, such as given by the 'Method 2 - Mass Optical Density' for engineering to performance requirements of the Appendix B (B-4.1.3.2) of NFPA Standard 72E edition 1999. Detectors of nominal sensitivity determined by tests as per European Norm 54 Part 7/9 or by Underwriters Laboratories Standard 268 will respond strictly to G-JET outputs at the worst case assumption of 100 % dilution in the smoke volumes. EN 54 Part 9 is used for the definition of effective sensitivity.
<i>Availability:</i>	Available in English, German and Norwegian languages at http://www.interconsult.com/G-Jet/ Runs in web browser.
<i>Price:</i>	Free
<i>Necessary Hardware:</i>	Web browser

Computer Language: Html/Visual Basic

Size: 10 MB

Contact Information: Geir Jensen gjen@cowi.no

Detailed Description:

G-JET is a design tool that calculates which category of smoke detector is most suitable and recommend initial nominal sensitivity setting required to detect a given amount of smoke fully dispersed in a given room or smoke volume. G-JET accepts all categories of smoke detector applications and is independent of product brands. It is based on simple formulas and assumptions. It works within typical national or international pre-scriptive standards for automatic fire detection, but also fully comply with the referred 'Method 2: Mass Optical Density' for engineering to performance requirements. G-JET lists default values of effective sensitivity (minimum mass of smoke released to be detected), but accepts specific values input by users according to stakeholder objectives or other.

G-JET was published at the AUBE '99 Conference on fire detection in Duisburg, March 1999. The book of Proceedings describes the model, definitions, formulas, design tool features and assumptions. The paper, an introductory description and a print-out sample is also available on the G-JET website <http://www.interconsult.com/G-Jet/>

The core of the model is the equation of optical density relating to mass of material transformed to smoke, fully diluted within a specified smoke volume and to room volume and simple, conservative assumptions. The simplicity and usefulness are the prime features of G-JET compared to elaborative design options such as CFD. G-JET calculates the effective sensitivity of any common smoke detection application using aspirating, beam or point type of detectors. Effective sensitivity relates to a mass of given material evenly dispersed as smoke in a room, in a defined smoke volume or in a defined 'cold plume cloud'.

It is a presumption both of the explanatory "Method 2" by NFPA and of G-JET that no thermal effects be present - it is the early pre-smokelayering phase, the pre-plume phase, that is being modeled. G-JET models the worst case challenge of smoke detection - that of fully dispersed smoke - as this is typically the most useful design criteria. Any

other smoke from fires is assumed to layer itself by plumes, typically towards the ceiling where it creates significantly higher optical densities - and at a later phase of fires when damage is more significant. In the plume-phase all listed detectors of nominal (sensor head) sensitivity rated within typical standards will respond reliably within a narrow time frame, thus not necessitating any response modeling for practical purpose.

